



DRINKING WATER ANALYSIS REPORTING FORM
STAGE 2 DISINFECTION BYPRODUCTS (TTHM&HAA5)

Individual Sample Report
*** Distribution System Only ***

*** PUBLIC WATER SYSTEM INFORMATION ***

>>>> TO BE FILLED OUT BY SYSTEM PERSONNEL <<<<

AZ04-14055
PWS ID Number

11/05/2024
Sample Date

Owner/Contact Email Address

SAMPLE TYPE

Compliance Monitoring

SITE ID (TTHM / HAA5):
01-A

Mohawk Valley School
PWS Name

Tim Burns
Owner/Contact Person

928-210-7730
Owner/Contact Phone Number

STAGE 2 Compliance Monitoring Site ID:
Workroom

*** DISINFECTION BYPRODUCTS ANALYSIS ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

Analysis Method	MCL	Reporting Limit	Contaminant Name	Cont. Code	Analysis Run Date	Result	Exceeds MCL
524.2		<0.0010	Chloroform	2941	11/06/2024	0.045	
524.2		<0.0010	Bromoform	2942	11/06/2024	0.0022	
524.2		<0.0010	Bromodichloromethane	2943	11/06/2024	0.031	
524.2		<0.0010	Dibromochloromethane	2944	11/06/2024	0.021	
524.2	0.080		TTHM	2950	11/06/2024	0.099	<input checked="" type="checkbox"/>
552.2		<0.0020	Monochloroacetic Acid	2450	11/10/2024	<0.002	
552.2		<0.0010	Dichloroacetic Acid	2451	11/10/2024	<0.001	
552.2		<0.0010	Trichloroacetic Acid	2452	11/10/2024	0.0011	
552.2		<0.0010	Monobromoacetic Acid	2453	11/10/2024	<0.001	
552.2		<0.0010	Dibromoacetic Acid	2454	11/10/2024	<0.001	
552.2 THAA	0.060		HAA5	2456	11/10/2024	<0.002	<input type="checkbox"/>

*** LABORATORY INFORMATION ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

550-225560-3
Specimen Number

Comment

Lab ID Number AZ0728 Lab Name Eurofins Phoenix Phone Number (602) 437-3340

Lab Contact, Printed Name Rebecca Reill

Authorized Signature *Rebecca Reill*

PWS Notification Date PWS Person Notified

All units must be reported in milligrams per liter (mg/L)

DWAR 32: Revised 12/2017

Submit completed form to:
EMAIL: WQD_Compliance_Data@azdeq.gov -or- MAIL: ADEQ Water Quality Compliance Data Unit (MC 5415B-1),
For questions call: (602) 771-9200 1110 W. Washington St., Phoenix, AZ 85007.